

Can the public access the Eli Whitney Fire Station testing data?

-Yes, the below charts detail test results from both Duke and NC State Laboratories.

**WATER WELL TESTING RESULTS FOR PFAS**

All concentrations in ng/L (ppt)	Eli Whitney Volunteer Fire Department, Inc.		
	Alamance		
Compound	104-1-D1-20250716	104-1-D1-20250716	104-1-N1
PFBA	42.7	51.0	51.7
PFPeA	123.9	140.4	
PFHxA	222.3	244.3	203.1
PFHpA	70.5	82.8	71.9
PFOA	83.5	93.6	82.0
PFNA	5.6	5.6	6.0
PFDA	1.7	1.7	1.3
PFUnDA	ND	ND	ND
PFDoA	ND	ND	ND
PFTTrDA	ND	ND	
PFTeDA	ND	ND	ND
PFBS	242.3	269.7	313.0
PFPeS	225.9	246.3	240.6
PFHxS	1385.0	1532.9	1581.1
PFHpS	62.5	67.1	36.5
PFOS	1225.5	1288.9	746.2
PFNS	ND	ND	ND
PFDS	ND	ND	ND
PFDoS	ND	ND	
FBSA	40.1	44.4	47.5
FHxSA	78.9	85.8	86.1
FOSA	ND	ND	ND
N-MeFOSAA	ND	ND	ND
N-EtFOSAA	ND	ND	ND
Bis-FMeSI	ND	ND	
Bis-FEtSI	ND	ND	
Bis-FBSI	ND	ND	
4:2 FTS	ND	ND	ND

<b>6:2 FTS</b>	17.2	18.3	16.2
<b>8:2 FTS</b>	ND	ND	ND
<b>10:2 FTS</b>	ND	ND	
<b>AmPr-FBSA/N-AP-FBSA</b>	ND	ND	
<b>AmPr-FPeSA/N-AP-FPeSA</b>	ND	ND	
<b>AmPr-FHxSA/N-AP-FHxSA</b>	ND	ND	
<b>AmPr-FOSA/N-AP-FOSA</b>	ND	ND	
<b>TAmPr-FHxSA/N-TAmP-FHxSA</b>	ND	ND	
<b>5:3 FTB</b>	ND	ND	
<b>5:1:2 FTB</b>	ND	ND	
<b>N-CMAMP-6:2 FOSA/6:2 FTAB</b>	ND	ND	
<b>N-AP-6:2 FOSA</b>	ND	ND	
<b>N-OxAmP-6:2 FOSA</b>	ND	ND	
<b>Sum PFAS</b>	<b>3,827.6</b>	<b>4,172.8</b>	<b>3,483.3</b>

**Adsorbable Organic Fluorine (AOF)**

Data generated at Duke University

Data generated at NCSU

Data generated at UNC Charlotte

NASEM 7 compound of concern